

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2021/ 451

Dated: 12.10.2021

To

The Deputy Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.

Subject:- Online Application ID No.- 2021083318696 in r/o Shree Rathnam Restaurant Pvt. Ltd. located at G-78, G.F. Vikas Marg, Preet Vihar, Delhi.


Sir,

This has a reference to online application ID No.- 2021083318696 dated 16/09/2021 received on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 24.09.2021 in the presence of Mr. Amit Yadav (Manager). During inspection following shortcomings were observed at site

1. MOEFA not provided.
2. Fire pump of 450 LPM not provided.
3. Overhead water capacity of 20,000 liter not provided.
4. Exit signage not provided.
5. Rear side iron staircase passing through Shree Rathnam Restaurant shall be segregated with brick wall.

Hence, Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Atul Garg)
Director

Delhi Fire Service



Copy to:-

Mr. Uday Kumar,
Shree Rathnam Restaurant Pvt. Ltd.
G-78, G.F. Vikas Marg, Preet Vihar, Delhi.