

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F.6/DFS/MS/School/SZ/2021/ 52

Dated: 03/02/2021

To,

The Vice-Principal
Sarvodaya Kanya Vidyalaya
Tughlakabad village. New Delhi-110044

Subject: Regarding renewal of Fire safety Certificate in r/o Sarvodaya Kanya Vidyalaya situated at Tughlakabad Village, New Delhi-110044


Sir,

This is in reference to your letter no 286/S.K.V.T.K.D.Village dated 31/12/2020 received in this department through outdoor diary no. 10246 dated 06/01/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection on 18/01/2021 in the presence of Mr. Virender Kumar (Estate Manager). The following shortcomings have been observed:

1. Hose reels found nonfunctional.
2. Terrace Fire pump found nonfunctional.
3. Exit Signage is missing at some places.

Keeping in view of above, Fire Safety Certificate cannot be considered at this stage

Yours faithfully



(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002