

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/EH/SZ/2021/ 460

Dated: 18/10/2021

To.

Sh. Naveen Gupta,
Jubilant Foodworks Ltd. (Domino's Pizza), S. No. 1,
Plot No.- 22B, Pusa Road, Bara Bazar, Rajender Palace, New Delhi.

Subject: - Regarding grant of Fire Safety certificate r/o Jubilant Foodworks Ltd. (Domino's Pizza), S. No. 1, Plot No.- 22B, Pusa Road, Bara Bazar, Rajender Palace, New Delhi.

Sir.

This has reference to your Online Application ID 2021030110862 dated 03.03 2021 on the subject cited above. Above said restaurants running at ground floor of a building comprised of basement, stilt, ground plus three upper floors. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on 18.03.2021 in presence of Mrs. Manju (Shift Manager).

During the course of inspection it has been observed that fire safety arrangements such as fire extinguishers, First aid hose reels, MOEFA, PA system etc. found provided. Wide the following shortcomings have been observed:-

1. Width of main door & alternate door provided 1.48 mts. each against requirement of 1.50 mts each.
2. Alternate door is passing through kitchen area which is not permitted, it should be segregated from kitchen area.

In view of the above shortcomings fire safety certificate cannot be considered at this stage. You are advised to rectify the above mention shortcomings and apply fresh for taking further necessary action.

Yours faithfully,

(Handwritten signature)
(Atul Garg)
Director
o/c

Copy to:-

1. The Joint. Commissioner of Police (Licensing Unit), 1st floor, Police Station, Defense Colony, New Delhi.