

c.6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: E.6/DPS/MS/11/2021/SZ /461
To,

Dated: 18/10/2021

Dy. Health Officer,
S.D.M.C, Public Health Department,
West Zone, Rajouri Garden, New Delhi 110027

Sub: - Regarding issuance of Fire Safety Certificate in respect of M/s Khalsa Parivar Restaurant, G-01, G-02, G-03, Ground Floor, 12 DDA Facility Centre, Mayapuri Phase-II, New Delhi-110064.
Sir,

This has reference to your Letter No. Application no. 2021082218530 dated 11/09/2021 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officers concerned of this department on 04/10/2021 to see the compliance of the requisite fire safety measures. Sh. Rohit (Manager) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of ground floor plus three upper floors but Khalsa Parivar restaurant is running at Ground Floor only. The following shortcomings were observed:-

1. Door width is 1.0 m & .75 m against required two doors having width 1.5 m each.
2. Hose reel system not provided.
3. MOEFA with talk back system not provided.
4. Internal hydrant system not provided.
5. Terrace fire pump of 450 LPM capacity not provided.
6. Overhead water storage tank of 20,000 ltrs capacity is not provided.
7. Exit signs are not provided.

Keeping in view of above, the building cannot be considered for issuance of fire safety certificate, at this stage. Therefore you are advised to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully



(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE



Copy to:-

1. M/s Khalsa Parivar Restaurant,
G-01, G-02, G-03, Ground Floor, 12 DDA Facility Centre,
Mayapuri Phase-II, New Delhi-110064