

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/Schools/NDZ/2021/ 576

Dated: 18/10/2021

To

The Principal,
Sri Guru Teg Bahadur Girls Sr. Secondary (S G T B Gr. Sr. Sec.) School,
Pulbangash, Delhi-06.

Ref: Email dated 07.10.21.

Sub: Issuance of Fire Safety Certificate to S G T B Gr. Sr. Sec. School.

Sir/ Madam,

With reference to the above mentioned request, your school was visited by the officer concerned of this department on 11.10.21 in presence of Mrs. Santosh (Vice Principal) and it was observed that the shortcomings issued to the school vide letter no. F6/DFS/MS/2018/ SCHOOL/2062 dated 16.05.2018 (copy enclosed) have not been rectified till date.

In view of the substantial non compliance of circular letter no. F 16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi, issuance of Fire safety certificate to the said school cannot be considered at this stage.

Yours faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Tel: 011-23412025

Enclosed: As above

Copy to:

1. The Director, Directorate of Education, Old Secretariat Building, Civil Lines, Delhi.

210

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2018/ School/2062

Dated 16/05/18

To,

The Principal,
Sri Guru Bahadur Girls Sr. School,
Pulbangash, Delhi - 110006

Sub: Regarding grant of FSC in r/o Sri Guru Bahadur Girls Sr. School,
Pulbangash, Delhi - 110006 (Gr. + Mezz. + 04 Upper floor).


Sir,

This has reference to your letter No. 86/18 dated 23/03/2018 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 28/04/2018 in the presence of Sh. Yatish Yadav (Lab Asstt.) and the following shortcomings were observed:-

1. One additional staircase to be provided.
2. Hose reel/hydrant not provided.
3. Fire pumps capacity of 450 LPM not provided.
4. Overhead water tank capacity of 10,000 liter not provided.
5. Exit signage not provided.

Hence, FSC cannot be considered at this stage.

Yours faithfully



(Sunil Chowdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director (Education),
Govt. of NCT, Old Sectt.
Delhi.

