## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADOLAND OF NATIONAL CAPITAL TERRITORY OF DELHI-HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2021/SZ/ 462

Dated 18/10/2021

To

The Dy. Health Officer, SDMC, South Zone, Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s The Tea Place (A Unit of Manjushree Plantations LTD) Shop No M-20, GF, M Block Market, Greater Kailash Part- II, New Delhi 110048 110048

Sir.

This has reference to your MHA Portal ID No. 2021082619206 dated 26/08/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.09.2021 in the presence of Mr. Navneet Kumar (Manager) to verify the fire safety measures installed in the building and observed that the restaurant is running at ground floor of the building. During inspection, following points were observed:

- There are two doors having width of 1.0 & 1.25 mtr against the required two doors having width of 1.50 mtr each. The second / alternative exit is passing through kitchen area which is not acceptable as per UBBL -2016.
- 2 First Aid Hose Reel Hose not provided.
- MOEFA Not provided.
- Internal hydrant not provided.
- 5 Terrace level Fire Pump capacity of 450 LPM not provided.
- Overhead tank capacity 20,000 ltrs not provided.
- 7 Exit signage not provided.
- Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully

and

Copy to:

1. The Joint C P (Lic.) 1st floor, P.S. Defence Colony, New Delhi 110049.

2. The Authorized Signature, M/s The Tea Place (A Unit of Manjushree Plantations LTD) Shop No M-20, GF, M Block Market, Greater Kailash Part- II, New Delhi 110048