

e5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No: F.6/DFS/MS/GH/2021/SZ. / 716

Dated: 18/10/2021

To,

Sh. Anil Vashist,  
M/s Vashist & Associates Guest House,  
J-35, Ganga Ram Vatika, Chaukhandi Road,  
Tilak Nagar, New Delhi-110018.

Sub: - Regarding issuance of fire safety certificate in respect of M/s Vashist & Associates Guest House  
at J-35 Ganga Ram Vatika, Chaukhandi Road, Tilak Nagar, New Delhi-110018.

Sir,

This has reference to your Letter ID No. 2021091121067 dated 14/09/2021 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officer concerned of this department on 28/09/2021 to see the compliance of the requisite fire safety measures. Sh. Anil Vashist (Owner) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Basement, Stilt, ground plus three upper floors. The following shortcomings were observed:-

1. Fire check door & Carbon monoxide detector are not provided as per Gazette Notification No. F.5(189)AD/LB/2016/4053-67 dated 27.05.2019 and letter no. F.5(189)AD/LB/2016/11940-55 dated 25.09.2019.
2. Exits signages are not provided.

Keeping in view of above, the building cannot be considered for issuance of fire safety certificate, at this stage. Therefore you are advised to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours Faithfully

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

The Addl. Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> Floor, Police Station,  
Defence Colony, New Delhi

