

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/GH/SZ/2021/ 735

Dated: 22/10/2021

To

The Owner/Occupier,  
M/s. Palm Springs Medispa & Stays,  
Plot no.- 60, Community Centre, Naraina, Phase-I,  
New Delhi- 110028.


Sub.-: Regarding renewal of Fire Safety Certificate in respect of M/s. Palm Springs Medispa & Stays (A unit of M/s. Palm Springs Cure Home & Research Centre Pvt. Ltd.), located at plot no.- 60, Community Centre, Naraina, Phase-I, New Delhi- 110028.

Sir,

Please refer to your Online application No. 2021091421385 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department, in presence of Sh. Harsimran Singh (owner) on 07.10.2021 to check the status of the shortcomings already pointed out by this department vide letter No. F6/DFS/MS/GH/SZ/2021/611 dated 09.09.2021. During the course of inspection, it was observed that the shortcomings are not complied.

In view of above, Fire Safety Certificate cannot be granted at this stage. You are requested to rectify the shortcomings under intimation to this department for further necessary action in this matter.

Yours faithfully



(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
o/c Delhi Fire Service



Copy to :-

The Joint. Commissioner of Police (Lic.),  
Police Station, Defence Colony, 1st floor,  
New Delhi.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/GH/SZ/2021/ 611

Dated: 09/09/2021

To  
The Joint. Commissioner of Police (Lic.),  
Police Station, Defence Colony, 1st floor,  
New Delhi.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Palm Springs Medispa & Stays (A unit of M/s. Palm Springs Cure Home & Research Centre Pvt. Ltd.), located at plot no.- 60, Community Centre, Naraina, Phase-I, New Delhi- 110028.

Sir,

Please refer to your online email Id [dcp-license@delhipolice.gov.in](mailto:dcp-license@delhipolice.gov.in) dated 28.07.2021, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 13.08.2021 in your presence of Sh. Harsimran Singh (owner), to check the functionability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus two upper floors served by two staircases having width 1.35 & 1.22 mts from basement to ground floor and 1.25 mts. each from ground to terrace floor. Fire safety arrangements such as overhead water tank capacity 10,000 lts, terrace pump, first aid hose reel, MOEFA, PA system, sprinkler system in basement floor, fire extinguishers, D.G.Set etc. found provided. However the following shortcomings were observed: -

1. Fire check doors found not provided in main staircase.
2. Found running a spa & gym in basement.

In view of the above shortcomings, renewal of the 'Fire Safety Certificate' cannot be considered at this stage. You are advised to rectify the above mentioned shortcomings under intimation to this department for further necessary action in this matter and running of guest house in absence of fire safety certificate will be at the owner's risk and responsibility.

Yours faithfully



(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to :-

The Owner/Occupier,  
M/s. Palm Springs Medispa & Stays,  
Plot no.- 60, Community Centre, Naraina, Phase-I,  
New Delhi- 110028.