

C19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/GH/2021/ 722

Dated 21/10/2021

To

Joint Commissioner of Police / Lic.
1st floor, Police Station
Defence Colony, New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Nirvana Hospitality Guest House, (A unit of Nirvana Suites) Plot No 87, Pocket-1, Jasola, New Delhi 110025.


Sir,

This has reference to MHA Portal ID 2021082819400 dated 28/08/2021 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department to verify the fire safety arrangements as stipulated in NBC Part-IV and as well installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

- 1 Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
- 2 Hose reel hose provided but not functional.
- 3 Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
- 4 Fire pump cap. 450 LPM found not functional at the time of inspection.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



**(SUNIL CHAUDHARY)
DY. CHIEF FIRE OFFICER**

Copy to:

1. M/s Nirvana Hospitality Guest House, (A unit of Nirvana Suites) Plot No 87, Pocket-1, Jasola, New Delhi 110025.