

C-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/School/NDZ/2021/ 583

Dated: 25/10/2021

To

Mr. D.V. Singh (Manager),
Happy Sr. Sec. School (Govt. Aided),
1226, Mahal Sarai, Bara Bazar,
Kashmere Gate, Delhi-06.

**Sub: - Regarding issuance of Fire Safety Certificate in r/o Happy Sr. Sec. School (Govt. Aided),
1226, Mahal Sarai, Bara Bazar, Kashmere Gate, Delhi-06.**

Sir,

With reference to email letter dated 06.10.2021 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (SPM) from this department on 13.10.2021 in the presence of Mr. D.V. Singh (Manager), and it was observed that the building is comprised of ground + 2 upper floors (school running on ground plus one upper floor only). During the inspection following shortcomings was observed: -

1. The school building is not accessible to fire engine as approach road width is less than 6 meters.
2. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Local Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Tel: 011-23414000

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.