

e-29
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2021/ 589

Dated: 28/10/2021

To,

Sh. Bore Gowda (Administration)
BGS International Public School,
Sec - 05, Dwarka,
New Delhi - 110075.

Subject: Renewal of Fire Safety Certificate in r/o BGS International Public School, Located at Sec - 05, Dwarka, New Delhi - 110075.

Sir,

Please refer to Email Dated 07/10/2021 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 13-10-2021 in presence of Sh. Bore Gowda (Administration) for fire safety point of view.


During the course of inspection the following shortcomings are noticed.

1. One staircase in basement found closed.
2. Exhaust fan in basement found removed.
3. Hose Reel Hose & hydrant found removed in basement.
4. Hydrants & Hose Boxes including branches & hoses are found removed at upper floors.
5. Stand by pump of capacity 1620 lpm found removed.
6. School activities are noticed in basement.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Sunil Chaudhary)
Dy. Chief Fire officer
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi - 110054
- 13/10/21*
27/10