

FT C-31

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2021/ 584

Dated: - 26/10/2021

To

The HOS,
Govt. Girls Sr. Sec. School,
West Patel Nagar, New Delhi-110008.

Sub.: - Regarding issuance of Fire Safety Certificate in r/o Govt. Girls Sr. Sec. School, West Patel Nagar, New Delhi- 110008, from fire safety and escape point of view.

Sir,

Please refer to your letter No. GGGSSS/WPN/FSC dated 20.09.2021 on the subject cited above. In this connection, it is to inform you that this department has already issued shortcoming letter in reply of your letter no. GGSSS/WPN/FSC/422 dated 17.03.2018 vide this department letter No. F.6/DFS/MS/School/SZ/2018/1793 dated 04.05.2018. The aforesaid school building have been re-inspected by the officer concerned of this department on 18.10.2021 in presence of Mr. Ratiram (Estate Manager), but no improvement was observed.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested again to rectify shortcomings as communicated vide letter dated 04-05-2018 (Copy enclosed) under intimation to this department.

Yours faithfully

(Sunil Chaudhary)

Dy. Chief Fire Officer (SZ)

o/c Delhi Fire Service

Copy to: -

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi-

for information please

C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2018/ 1793

Dated: - 04/05/18

To,

The Head of the School,
Govt. Girls Senior Secondary School,
West Patel Nagar, New Delhi- 110008.

Sub.-: Regarding issuance of Fire Safety Certificate in r/o Govt. Girls Sr. Sec. School, West Patel Nagar, New Delhi- 110008.

Sir,

Please refer to your letter No. GGSSS/WPN/FSC/422 dated 17.03.2018 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in the presence of Sh. Gopal, chowkidar of the school on 10/04/2018 to check the status of the shortcomings already pointed out by this department vide letter no. F.6/DFS/MS/School/2015/1934 dated 21.08.2015, and status is as under: -

Sr. No.	Shortcomings	Status
1.	The first aid hose reels are provided but not functional	Not provided
2.	Down comer system is provided but not functional	Not Provided
3.	Two fire pumps of 450 LPM discharge with 30 mts head each are provided but not functional.	Not Provided
4.	The overhead water storage tank of 10000 lts cap is provided but empty.	Not Provided
5.	Exit signs are not provided in the school building	Not Provided

In view of the above, 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

W. J. S.

(VIPEN KENTAL)
CHIEF FIRE OFFICER

Copy to: -

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi

for information please

9c
26/4/18