

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/School/2021/ 57

Dated: 05 /02/2021

To

The Principal,
New Sun Ideal Public school,
T-505, Chamelian Road, Delhi-110006

**Sub: Regarding Renewal of FSC in r/o New Sun Ideal Public School located at T-505,
Chamelian Road, Delhi-110006.**

Sir,

This has reference to your e-mail <new_sun_education@Yahoo.com> dated 25/12/2020 on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 01.02.2021 in the presence of Mr. Rizwan and observed that alternate staircase at IInd and IIIrd floor is still not provided as communicated earlier vide letter NO. F6/DFS/MS/School/2020/ 668 dated 06.10.2020.

In view of above, fire safety certificate (FSC) cannot be renewed at this stage .

Yours faithfully



(Dr. S.K.Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director (Education),
Govt. of NCT, Old Sectt.
Delhi - 54.

