

c 5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2021/SZ/ 473

Dated: 28/10/2021

To
The Joint Commissioner of Police, (Lic)
1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Issuance of NOC in r/o M/s Jubilant Foodworks Limited (A Unit of Hongs Kitchen or Ek Dum) E-249, Ground Floor, Subedar Bhawan Rama Market, Munirka Village, New Delhi-110067


Sir,

This has reference to your MHA Portal ID 2021091721721 dated 17/09/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 13.10.2021 in the presence of Sh. Danish (Manager) to verify the fire safety measures installed in the building and observed that the restaurant is running at Ground floor of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid Hose Reel not provided.
2. Internal hydrant not provided.
3. Terrace level pumps capacity 450 LPM not provided.
4. Overhead tank capacity 20,000 ltrs not provided.
5. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to:-

1. M/s Jubilant Foodworks Limited (A Unit of Hongs Kitchen or Ek Dum) E-249, Ground Floor, Subedar Bhawan Rama Market, Munirka Village, New Delhi-110067