

- 65 64

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2021/ 744

Dated: 27/10/2021

To,  
The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **Ashiana Guest House, 1366, Ballimaran, Delhi.**

**Sir,**

This has reference to online application I.D. no. 2021100123111 dated 01.10.2021 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 13.10.2021 in the presence manager and it was observed that the building is comprised of **ground + mezzanine + 3 upper floors**. During inspection following shortcomings were observed.

1. Mezzanine floor was found being used as dormitory (with 12 beds) in contradiction to the undertaking dated 22.10.2019 and affidavit dated 18.11.2019, submitted by the owner stating closure of mezzanine floor.
2. The building plan uploaded with the online application has not been signed & stamped by a registered architect and owner.
3. 03 fire extinguishers are provided in place of requirement 06 fire extinguisher.
4. C.O detectors is required as per Gazette Notification dated 27.05.2019 at each guest room and common areas..
5. Exit signages not provided.

In view of above shortcomings and submission of false undertaking & affidavit, the application no. 2021100123111 (for issuance for Fire Safety Certificate) is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Local Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


  
(Atul Garg)

Director

Tel: 011-23414000.

**Copy to:-**

The Licensee, Ashiana Guest House, 1366, Ballimaran, Delhi.

  
21/10/21 27/10/21