

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2021/ 588

Dated: - 28/10/2021

To,

The HOS/ Principal,
S.D. Public School,
Patel Nagar, New Delhi-110008.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o S.D. Public School, located at Patel Nagar, New Delhi- 110008, from fire safety and escape point of view.


Sir,

Please refer to your online email Id sdpscpn@gmail.com dated 27.09.2021 on the subject cited above. In this connection, it is to inform you that the aforesaid school building is consisting of two blocks, each blocks are comprised of ground plus two upper floors. School building have been inspected by the officer concerned of this department in presence of Mrs. Dr. Meenakshi (HOS/Principle) on 18.10.2021.

During the course of inspection, it was observed that according to FSC given by this department vide letter no. F.6/DFS/MS/School/SZ//2017/933 dated 29.06.2017, first block of the building comprised of ground plus one upper floor & second block comprised of ground plus two upper floors. At the time of inspection it was observed that first block of the building constructed one additional floor i.e. second floor. It is a case of addition/alteration in First Block. This department has already issued a letter in this matter vide this office letter No. F.6/DFS/MS/School/SZ/2021/42 dated 28.01.2021 (copy enclosed).

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested again to submit sanctioned plan of first block, if any, to this department for further action in the matter.

Yours faithfully



(Sunil Chaudhary)
Dy. Chief Fire Officer
South Zone

Copy to: -

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi- for information please

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2021/ 42

Dated: - 28/01/21

To,

The HOS/ Principal,
S.D. Public School,
Patel Nagar, New Delhi-110008.

Sub.-: Regarding renewal of Fire Safety Certificate in r/o S.D. Public School, located at Patel Nagar, New Delhi- 110008, from fire safety and escape point of view.

Sir,

Please refer to your letter Form 'J' dated nil on the subject cited above. In this connection, it is to inform you that the aforesaid school building is consisting of two blocks, each blocks are comprised of ground plus two upper floors. School building have been inspected by the officer concerned of this department in presence of Mrs. Dr. Meenakshi (HOS/Principle) on 22.12.2020 to check the fire safety arrangements already provided in the building.

During the course of inspection, it was observed that according to FSC given by this department vide letter no. F.6/DFS/MS/School/SZ//2017/933 dated 29.06.2017 first block of the building comprised of ground plus one upper floor & second block comprised of ground plus two upper floors, but at the time of inspection it was observed that first block of the building constructed one additional floor i.e. second floor. It is a case of addition/alteration in first Block.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to submit sanctioned plan of first block if any to this department for further action in the matter.

Yours faithfully



(Sunil Chaudhary)
Dy. Chief Fire Officer
9/C, South Zone

Copy to: -

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat, Delhi- for information please