

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/EH/2021/SZ/ 484

Dated: 01/11/2021

To,

Dy. Health Officer (West Zone),
SDMC, Officer of the Dy. Health Officer,
Rajouri Garden, New Delhi-110027.

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Kitchen Klub, Shop No. 12 A, First Floor, DDA Facility Centre Mayapuri Phase-II, New Delhi-110064.

Sir,

This has reference to your online application no.2021090420221 dated 10/09/2021 on the subject captioned above. In this connection, it is to inform you that the above mentioned eating house was inspected by the officer concerned of this department on 30/09/2021 in the presence of Sh. Rohit (Manager) to verify the compliance of shortcoming already communicated by this department vide letter no.F6/DFS/MS/EH/2020/SZ/655 dated 30/06/2021 and observed that shortcomings are still not rectified. The management will be held responsible for any untoward incident for the period if compliance is not made.

Yours faithfully

(Sunil Chawdhary)
Dy. Chief Fire Officer

Copy to:-

1. M/s Kitchen Klub,
Shop No. 12 A, First Floor, 12 DDA Facility Centre
12 DDA Facility Centre, Mayapuri Phase-II, New Delhi-110064

28
C-8

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/EH/2020/SZ /655
To,

Dated: 30/06/2020

Dy. Health Officer,
S.D.M.C, Public Health Department,
West Zone, Rajouri Garden, New Delhi-110027

Sub: - Regarding issuance of Fire Safety Certificate in respect of M/s Kitchen Klub, Shop No. 12
A, First Floor, 12 DDA Facility Centre, Mayapuri Phase-II, New Delhi-110064.
Sir,

This has reference to your Letter No. Application no. 2020052705093 dated 01.06.2020 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by officers concerned of this department on 17.06.2020 to see the compliance of the requisite fire safety measures. Sh. Rohit (Manager) was present at the time of inspection.

During the course of inspection it was observed that the building comprised of ground floor plus three upper floors but Kitchen klub restaurant is running at First Floor only. The upper floor is served by single staircase having width 110 cms. The building is approachable to the fire fighting vehicles. The electrical wiring was seen concealed and the electric supply was passing through MCB's. The following shortcomings were observed:-

1. The upper floor is served by single staircase having width 110 cms against required two staircases having width 200 & 150 cms each.
2. Door width is 100 cms & 75 cms against required two doors having width 200 cms and 150 cms.
3. Ventilation system not provided in the restaurant hall.
4. Hose reel system not provided.
5. MOEFA with talk back system not provided.
6. Internal hydrant system not provided.
7. Terrace fire pump of 450 LPM capacity not provided.
8. Overhead water storage tank of 20,000 ltrs capacity is not provided.
9. Exit signs are not provided.

Hence the owner may be advised to rectify the above-mentioned shortcomings under intimation to this department for taking further action as necessary for grant of Fire Safety Certificate.

Yours Faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. M/s Kitchen Klub,
Shop No. 12 A, First Floor, 12 DDA Facility Centre
12 DDA Facility Centre, Mayapuri Phase-II, New Delhi-110064
2. Dy. CFO (FPW), HQ, Delhi Fire Service (for online updation)