

C-46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 2021/ 757

Dated:- 01/11/2021

To,

The Manager,
Geetanjali Inn,
3997- 4000&4001, Gali School Wali,
Mohalla Kaseruwalan, Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Geetanjali Inn, 3997- 4000&4001 Bagichi Ram Chander, Kaseruwalan, Pahar Ganj, New Delhi. ID No. 2021090520255 dated 05.09.21.

Sir,

This has reference to on line ID No. 2021090520255 dated 05.09.21. on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 23/10/2021 in the presence of Mr. Mustakh and following shortcomings were observed: -

1. Smoke venting arrangements are not provided as per Gazette Notification dated 27.05.2019.
2. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.