

242

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/NDZ/2021/ 762

Dated: 02.11.2021

To

The Manager,
Hotel Mahajan Place, 10830,
Jhandewalan Road, Chowk Motia Khan,
New Delhi.

Subject:- Online Application ID No.- **2021090820601** in r/o M/s Hotel Mahajan Place located at **10830, Jhandewalan Road, Chowk Motia Khan, New Delhi.**

Sir,

This has a reference to online application ID No.- **2021090820601** dated 08.09.2021 on the subject cited above. In this connection, it is to inform you that the online application has been examined and observed that the details mentioned in performa having deficiencies in r/o following points.

1. The number rooms floor wise mentioned in Performa does not match with building plans as uploaded on the portal, same may clarified.
2. Number of staircase & width of door mentioned in application form is not matching with building plan.
3. Section/elevation plans is not submitted for verify the height of building as height of building is mentioned in the Performa 15 meter. Building plan is also not signed by the architect.

Further, the compliance of Gazette notification dated 27.05.2019 is also not submitted.

Therefore, the applicant may be directed to furnish correct information & resubmit the application with the compliance of Gazette notification dated 27.05.2019 for further consideration in the matter. The online application is **deficient** in respect of above shortcomings.

Yours faithfully,


2/11/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Ph. No. 011-23412025

Copy to:-

The Addl. Commissioner (Licensing)
1st Floor, Police Station Defence Colony,
New Delhi.