

DFA 114
C-5.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/SZ/2021/ 477

Dated: 01/11/2021

To,

Sh. Vijay Subramanian (Owner),
M/s. Nellai Annapoorna Restaurant,
15A/17, WEA, Saraswati Marg, Karol Bagh, New Delhi- 05.

Sub.: Regarding issuance of FSC in respect of M/s. Nellai Annapoorna Restaurant located at 15A/17, WEA, Saraswati Marg, Karol Bagh, New Delhi- 05.

Sir,

Please refer to your online application ID 2021080717171 dated 08.10.2021 on the subject cited above. In this connection, it is to inform you that the aforesaid restaurant has been inspected by the officer concerned of this department on 14.10.2021 in the presence of Sh. Vijay Subramanian (Owner), to check the fire safety arrangements provided in the building.

During inspection, it has been observed that the said restaurant is running at ground floor of a building comprised of basement, ground plus three upper floors. No fire safety arrangements found provided except some fire extinguishers. However the following fire safety arrangements are required: -

1. One exit door found provided width of 2.0 mts. against required two exits with width 1.50 mts. each.
2. Fire Check Doors are not provided in kitchen.
3. First aid hose reel hose found not provided.
4. MOEFA is not provided.
5. P.A system found not provided.
6. Down Comer is found not provided.
7. Terrace pump capacity 450 LPM is found not provided.
8. Overhead tank capacity 20,000 lts exclusively for firefighting purpose, is required.
9. Exit signages are not provided at the places mentioned during the inspection.

In view of the above shortcomings, 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the shortcomings under intimation to this department.

Yours faithfully

(Atul Garg)
Director

o/c Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police, Licensing Unit, 1st Floor, Police Station, Defence Colony, New Delhi- 110049.
2. The Executive Engineer (Building), North MCD, Karol Bagh, Anand Parbat, New Delhi.