

296

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 2021/ 765

Dated: 02.11.2021

To,

The Manager,
Silver Shine Guest House,
1323-1328, Sangatrashan Chowk,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Silver Shine Guest House located at 1323-1328, Sangatrashan Chowk, Pahar Ganj, New Delhi. ID No. 2021091421399 dated 18.09.21

Sir,

This has reference to on line ID No. 2021091421399 dated 18.09.21 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 27/10/2021 in the presence of Mr. Harvinder and following shortcomings were observed: -

1. Fire check doors on the staircases are not provided as per Gazette Notification dated 27.05.2019.
2. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defence Colony New Delhi.