

363

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/ 2021/ 764

Dated:-02.11/2021

To,

The Manager,  
Toto International Guest House,  
4824-25, 6, Tooti Chowk, Pahar Ganj,  
New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Toto International Guest House  
at 4824-25,6, Tooti Chowk, Pahar Ganj, New Delhi.**

Sir,

This has reference to on line ID No. 2021091921922 dated 19.09.21. on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 27/10/2021 in the presence of Mr. Aki Rathi and following shortcomings were observed: -

1. Smoke venting arrangements are not provided as per Gazette Notification dated 27.05.2019.
2. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter, as last date for compliance of notification was 30.09.2021.

Yours faithfully,



**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.