

e63

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 763

Dated: 02.11.2021

To,

The Manager
Venus International,
1925-27, Gali No-10, Chuna Mandi,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Venus International, 1925-27, Gali No-10, Chuna Mandi, Pahar Ganj, New Delhi. ID No. 2021090820705 dated 08.09.2021.

Sir,

This has reference to on line ID No. 2021090820705 dated 08.09.2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 26/10/2021 in the presence of Mr. Rajendra Paul and following shortcomings were observed: -

1. Smoke venting arrangements are not provided as per Gazette Notification dated 27.05.2019.
2. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.
3. Hose reel is not provided at ground floor.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage due to above shortcomings. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

