

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/EH/NDZ/2021/ 496

Dated 02.11/2021

To,

The Manager,
M/S Cha-Bar (A unit of Apeejay Oxford Book Stores (Pvt.) Ltd.)
N-81, F.F., Connaught Place, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Cha-Bar (A unit of Apeejay Oxford Book Stores (Pvt.) Ltd) located at N-81, F.F, Connaught Place, New Delhi. ID No. **2021092622599** dated 26.09.2021.

Sir,

This has a reference to online ID No **2021092622599** dated 26.09.2021 on the subject cited above, it is to inform you that the site was inspected by the officers concerned department on 12/10/2021 in the presence of Sh. Nitin Warikoo and the following shortcomings were observed:-

1. 02 Staircases of 1.5 meter each are not provided.
2. 02 Exits of 1.5 meter each are not provided.
3. First aid hose reel and hydrant systems are not provided.
4. MOEFA is not provided.
5. Terrace pump of 450 LPM is not provided.
6. Overhead fire water tank of 20,000liter capacity is not provided.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully



(Anil Garg)
DIRECTOR
Delhi Fire Service



Copy to :-

The Addl. Commissioner of Police (Lic.),
Licensing Unit, Defence Colony Police Station, New Delhi