

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2021/NDZ/ 600

Dated: 02/11/2021

To,

The Principal,
EDMC Primary School,
Jagatpuri, G-Block, Delhi-110051

Subject:- Request for issue NOC for fire work.

Sir,

With reference to email ID eee2shahnorthzone@gmail.com dated 04/10/2021 on the subject cited above, it is informed that officer concerned of this department visited the school building on dated 25/10/2021 and observed that the shortcomings issued vide letter No. F.6/DFS/MS/School/2015/1589 dated 17/07/2015 and No. F.6/DFS/MS/School/2016/677 dated 16/03/2016 have not been complied as yet (The copy of the same is enclosed for reference).

In view of the above Fire Safety Certificate cannot be considered at this stage. You are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Director of Education, EDMC,
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi-110092

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI-110 001

No.

E6/ops/ms/school/2016/677

Dated

16/03/16

To,

The Principal (2nd Shift)
EDMC Primary School,
Jagatpur, G -Block, Delhi-51

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o EDMC Primary School, Jagatpur, G -Block, Delhi-51
Madam,

Please refer to letter dated 29.02.2016 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection on 03.03.2016 Principal was present and it was observed that the shortcomings as communicated earlier vide letter dated 17.07.2015 are yet to be rectified. The copy of the same is enclosed for reference.

Yours faithfully



(Rajesh Panwar)

Dy. Chief Fire Officer

Ph. 011-23412025

RP

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI-110 001

No. 66/2015/MS/Service/2015/1588

Dated 17.07.15

To,
The Principal (2nd Shift)
EDMC Primary School,
Jagatpuri, G -Block, Delhi-51

Sub: - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o EDMC Primary School, Jagatpuri, G -Block, Delhi-51
Madam,

Please refer to your letter dated 05.06.2015 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the Delhi Fire Service Act, 2007 and Rules 2010. At the time of inspection Principal was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings. -

1. The School is not accessible to fire engines as approach road width is less than 6 meters.
2. An additional staircase is required.
3. First Aid Hose reels not provided.
4. Fire pump having capacity 450 LPM out put at 40 m head not provided.
5. Over head water storage tank 10,000 liters capacity for firefighting not provided.
6. Exit signs not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under intimation to this department for further course of action.

Yours faithfully


(Rajesh Panwar)

Dy. Chief Fire Officer
Ph. 011-23412025

Copy to:-

- 1 The Director of Education,
East Delhi Municipal Corporation,
419, Udyog Sadan, Patparganj Industrial Area, Delhi-92
2. The Principal (1st Shift)
EDMC Primary School, Jagatpuri, G -Block, Delhi-51