

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

No. F6/DFS/MS/WZ/2021/490

Dated: 02/11/2021

To,

The Joint Commissioner (Lic.),
 1st Floor, Defence Colony Police Station,
 Defence Colony, New Delhi.

Subject: Inspection report in respect M/s. Jungle Jamboree, FF, A-23, Vishal Enclave, Rajouri Garden, Delhi- 110027.

Sir,

This is in reference to the online application received through MHA portal vide ID-2021033011755 on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 06.10.2021 in the presence of Sh. Sandeep (manager) to check the provisioning of fire safety arrangements provided in the building. During the course of inspection, it was observed that the said restaurant is running at 1st floor of a building comprised of Basement, Ground, mezzanine, first floor, mezzanine and second floor, served by single staircase having width 1.30-1.50 mts. No fire safety arrangements found provided except few fire extinguishers. However, following fire safety arrangements are required: -

1. Two nos. of staircases having width of 1.5 mts each.
2. Width of door size is less than required width of 1.5 mts each.
3. Terrace Fire pump capacity 450 is required.
4. Overhead tank capacity 20000 lts is required.
5. Down comer system is required.
6. Exit signages on the places mentioned during the inspection are required.
7. MOEFA & MCP are required.
8. Lift shall be segregated with Fire Check Door.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority /statutory authority is requested that premises should not be allowed to run till its provide all necessary fire safety arrangements.

Yours faithfully


 (Atul Garg)
 Director

Delhi Fire Service

Copy to: -

1. The Deputy Health Officer, South MCD, Shivaji Enclave, Raja Garden, New Delhi.
2. The owner/occupier, M/s. Jungle Jamboree, FF, A-23, Vishal Enclave, Rajouri Garden, Delhi- 110027.