

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/SZ/499

Dated: 02/11/2021

To

Mr. Sidhant Kalra,
M/s Khan Chacha,
(A Unit of Gupta & Gupta Pvt. Ltd),
FC-04, Ground Floor, LGF, Worldmark-I,
Aerocity, New Delhi-110037


Sub: **Inspection report in respect of M/s Khan Chacha (A Unit of Gupta & Gupta Pvt. Ltd),
FC-04, Ground Floor, LGF, Worldmark-I, Aerocity, New Delhi -110037**

Sir,

This is with reference to online application ID: 2021071515245 dated 20/07/2021, on the subject cited above. In this connection, the premise was visited by the officer concerned of this department on dated 11/10/2021 in presence of Mr. Angad (Outlet In-charge) to verify the compliance of shortcoming communicated vide this department letter No. F6/DFS/MS/EH/2020/913 dated 17/12/2020 and observed that the shortcoming has not yet complied.

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premise in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

07c 50

Copy to: -

1. The Addl. Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi-110049
2. The Dy. Health Officer (NGZ), South Delhi Municipal Corporation, Public Health Department, Dhansa Bus Stand, Najafgarh, New Delhi-110043

c/6

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. *86/Dfs/ms/EH/2020/913*

To,

Dated: *17/12/2020*

Authorized Signatory,

M/s Khan Chacha,

(A Unit of Gupta and Gupta Pvt. Ltd),

FC-04, Ground Floor, Street LGF Worldmark-1,

Aerocity, Delhi-110037.

Subject: Inspection report of M/s Khan Chacha (A Unit of Gupta and Gupta Pvt. Ltd), FC-04, Ground Floor, Street LGF Worldmark-1, Aerocity, Delhi-110037 from Fire Safety and means of escape point of view.

Sir,

Please refer to your MHA ID-2020100307395 dated 16/10/2020 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 30.11.2020 in the presence of Sh. Angad (Outlet Incharge) and observed that outlet is situated on lower ground floor of Worldmark-1 building. Total covered area of the restaurant at the lower ground floor is 108 m² and as per NBC (Part-IV) the no. of occupants comes out to be 60 (108/1.8=60). Thus capacity of restaurant is 60 persons which is covered under DFS Act 2007, Rules 2010. Subsequently inspection of Eating House is carried out as per NBC (Part-IV) and following shortcoming is observed:-

1. One door of width 0.88 mtr is provided against requirement of 2.00 mtr width & 1.50 mtr width.

In view of above NOC/FSC is rejected under Rule 35 (3) of DFS Act 2007, Rules 2010.

You are requested to rectify above mentioned shortcoming under intimation to this department for further necessary action please.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to:-

1. Dy. Commissioner of Police (Licensing), Police Station, 1st Floor, Defence Colony, New Delhi-110049.
- D.H.O. SDM/C, Najafgarh Zone, Najafgarh, New Delhi-110043