

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2021/ 489

Dated:- 01/11/2021

To

The Manager,
M /S Nizams Kathi Kabab (Amir Chand and Sons HUF),
Ground Floor, H-5, Plaza Cinema Building,
Middle Circle, Connaught Place, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Nizams Kathi Kabab (Amir Chand and Sons HUF) located at at Ground Floor H-5, Plaza Cinema Building, Middle Circle, Connaught Place, New Delhi.

Sir,

This has reference to online ID No. 2021083119660 dated 01.09 21 on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 12/10/2021 in the presence of Sh. Prakash Kanpal and following shortcomings were observed:-

1. 02 Exits of 1.5 meter each are not provided.
2. First aid hose reel and hydrant systems are not provided.
3. MOEFA is not provided.
4. Terrace pump of 450 LPM is not provided.
5. Overhead fire water tank of 20,000liter capacity is not provided.
6. Exit signages are not provided (Indequate).

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi