

25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2021/ 492
To

Dated 02/11/2021

Sh. Balram (Manager)
Tata Starbucks (Coffee House)
Shop No. 25UA, Ground Floor,
Jawahar Nagar, Malka Ganj, Delhi-110007.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Tata Starbucks, Shop No. 25UA, Ground Floor, Jawahar Nagar, Malka Ganj, Delhi-110007.

Sir,


This has reference to your online I. D. No. 2021092922844 dated 04.10.2021 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.10.2021 in the presence of Mr. Balram (Manager) to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection it has observed that the building/ premise is comprised of basement, ground & 03 upper floors (Restaurant at ground floor only). Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

- 1 There are two exit doors having width of 1.60m, & 1.40m provided against requirements of 1.50m each.
- 2 Hose reel hose not provided.
- 3 Internal hydrants not provided. Hose boxes not provided.
- 4 Terrace pumps capacity of 450lpm provided but not functional. The pumps are not on auto mode.
- 5 Terrace level fire water tank capacity of 20,000ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
- 6 Exit signage's not provided in the building.
- 7 Standby power supply not provided.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You may apply again on form 'I' as stipulated in sub rule (2) 35 of rules, DFS Rules 2010 after compliance of the shortcoming mention above. The link for forms is as under available on <http://delhi.gov.in./wps/wcm/connect/doiit fire/FIRE/Home/Forms>.

Yours faithfully


(Atul Garg)
Director

Ph: 011-23414000


Copy to:

1. The Dy. Health Officer, Civil Line Zone, 16, Rajpura Road, Delhi-110054.
2. The Additional Commissioner of Police/Lic, 1st Floor, PS Defence Colony, New Delhi.