

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2021/498

Dated 02/11/2021

To

The Dy. Health Officer,
 SDMC, South Zone,
 Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o The Beer Café (A Unit of BTB Marketing Pvt LTD) Shop No M-4 First Floor, M Block Market, Greater Kailash Part- II, New Delhi 110048

Sir,

This has reference to your MHA Portal ID No. 2021090119724 dated 01/09/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.09.2021 in the presence of Mr. Kamal (Manager) to verify the fire safety measures installed in the building and observed that the restaurant is running at first floor of the building. During inspection, following points were observed:

- 1 There are two staircases having width of 1.50m & 1.0 m provided against the requirement of two staircase width of 1.50 mtr each respectively.
- 2 There are two doors having width of 1.25 & 1.0 mtr against the requirement of two doors having width of 1.50 mtr each.
- 3 Hose reel not provided.
- 4 Internal hydrant not provided.
- 5 Terrace level Fire Pump capacity of 450 LPM not provided.
- 6 Overhead tank capacity 20,000 ltrs not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit

Yours faithfully


 (ATUL GARG)
 DIRECTOR

Copy to:

1. The Joint C P (Lic.) 1st floor, P.S. Defence Colony, New Delhi 110049
2. The Authorized Signature, The Beer Café (A Unit of BTB Marketing Pvt LTD) Shop No M-4 First Floor, M Block Market, Greater Kailash Part- II, New Delhi 110048