

G 17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/School/2021/SZ /605

Dated: 09/11/2021

To,

The Manager,
Arya Kumar Convent School,
Durga Vihar, Phase-1, Roshanpura, Najafgarh New Delhi-110043

Sub: -Regarding issuance of fire safety certificate in respect of M/s Arya Kumar Convent School,
Durga Vihar, Phase-1, Roshanpura, Najafgarh, New Delhi-110043.


Sir,

Please refer to your letter no. Nil Dated -15/10/2021 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building on 25/10/2021 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Mr. Rakesh Kumar (Managing Director) was present and it was observed that the building is comprised of ground plus two upper floors and have following shortcomings:-

1. First aid hose reel provided but not functional.
2. Down comer system provided but not functional.
3. Fire pump provided but not functional.
4. Exits signage's are not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours Faithfully


(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054

