

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. 86/DHS/MS/ETH/2021/480

Dated: 01/11/2021

To,

Sh. Navneet Kalra,  
M/s M/s Choy (A Unit of RNV Hospitality),  
Flat No.-15, 1<sup>st</sup> Floor & 2<sup>nd</sup> Floor, Khan Market, New Delhi.

**Subject: Inspection report of M/s M/s Choy (A Unit of RNV Hospitality) Flat No.-15, 1<sup>st</sup> Floor & 2<sup>nd</sup> Floor, Khan Market, New Delhi, from Fire Safety and means of escape point of view.**

Sir,

Please refer to your MHA portal ID-2020100107372 dated 13/02/2021 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 27/02/2021 in the presence of Sh. Rohit Sharma (Manager) and observed following shortcomings during the inspection:-

1. Only one staircase of width 0.95m is provided against requirement of 2 No. of staircase having width 1.50mtr each.
2. Hose reel hose not provided.
3. Internal Hydrant not provided.
4. Over Head Tank of 5,000 ltr is provided against requirement of 20,000 ltr capacity.

In view of above NOC/ FSC cannot be considered at this stage.

You are requested to rectify above mentioned shortcomings under intimation to this department for further necessary action please.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR.

Copy to:-

1. Joint Commissioner of Police (Lic), 1<sup>st</sup> Floor, PS defence colony, New Delhi-110049.