

G 68

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2021/ 771

Dated:-08./11./2021

To,

The Manager,  
**Rachna Tourist Lodge**, Guest House,  
8510, Arakashan Road, Pahar Ganj,  
New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Rachna Tourist Lodge, Guest House, located at 8510, Arakashan Road, Pahar Ganj, New Delhi** Online id no. 2021092722693 dated 28/09/2021.

Sir,

This has reference to Online id no. 2021092722693 dated 28/09/2021, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 29/10/2021 in the presence of Mr. Ravinder (Manager) and following shortcomings were observed: -

1. Fire Check Door of 01 hr. rating on the staircase are not provided as per Gazette Notification dated 27.05.2019.
2. Smoke Management system is not provided as per Gazette Notification dated 27.05.2019.
3. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully,

  
57/11/21

**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service



**Copy to :-**

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.