

218

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001**

No.F6/DFS/MS/School/NDZ/2021/ 604

Dated: 08/11/2021

To

Mrs. Makya Kamal, (Vice Principal),  
Govt. Girls Sec. School (U.M.),  
Lambi Gali, Hauz Qazi, Delhi-06 (School ID no. 2127031).

**Sub:-** Regarding issuance of Fire Safety Certificate in r/o **Govt. Girls Sec. School (U.M.), Lambi Gali, Hauz Qazi, Delhi-06 (School ID no. 2127031).**

Sir,

With reference to email letter dated 25.10.2021 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (SPM) from this department on 03.10.2021 in the presence of Mrs. Makya Kamal (Vice Principal) and it was observed that the building is comprised of ground + 3 upper floors. During the inspection following shortcomings were observed:-

1. The school building is not accessible to fire engine as approach road width is less than 6 meters.
2. First-aid-hose reels not provided.
3. Fire pump having capacity 450 LPM & head 40 mtrs. not provided.
4. Overhead tank capacity 10,000 liters for firefighting not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
5/11/21

**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Tel: 011-23412025

**Copy to:-**

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.

e/c   
05/11/21