

G-158

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/ 2021/ 773

Dated:-08/11/2021

To,

The Manager,
India International Dx. Guest House,
2485-87, Nalwa Street, Chuna Mandi,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S India International Dx. Guest House,
2485-87, Nalwa Street, Chuna Mandi, Pahar Ganj, New Delhi. ID No.21091421401 dated
18.09.21.

Sir,

This has reference to on line ID No. 2021091421401 dated 18.09.21 on the subject
cited above. In this regard, it is to inform you that the site was inspected by the officers
concerned of this department on 29/10/2021 in the presence of Mr. Roshan lal and following
shortcomings were observed: -

1. Fire Check Door of 01 hr. rating on the staircase are not provided as per Gazette
Notification dated 27.05.2019.
2. Smoke Management system is not provided as per Gazette Notification dated
27.05.2019.
3. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are
requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully,



(Dr. S.K.Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.