

c 5

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2021/SZ/ 770

Dated: 08/ 11 /2021

To

Authorized Signatory,
M/s Maruti Inn, 11-A,
Nangli Razapur, East Nizamuddin,
New Delhi-110013.

Sub.- Fire Safety Certificate in r/o M/s Maruti Inn, 11-A, Nangli Razapur, East Nizamuddin, New Delhi-110013.

Sir,

With reference to your MHA portal App. No.-2021100623467 dated 06/10/2021 on the subject noted above, in this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 22.10.2021 in the presence of Sh. Ankit (Manger).

During the course of inspection it was observed that the building premises is comprised of Basement, Ground + 4 Upper Floors but Guest House is proposed on 1st Floor, 2nd Floor & 3rd Floor only (3 Rooms on Each Floor).

However following shortcomings were observed during the time of inspection:-

1. Only one staircase of width 0.86mtr is provided against requirement of 2 staircase of 1.50mtr each.
2. Width of the door is 0.86mtr against requirement of 1.50mtr.
3. Hose reel hose, Fire Pump of 450 Ltr /Min. capacity and Terrace tank of 5,000 ltr capacity not provided.
4. Fire check doors not provided.
5. Detector of Carbon Mono oxide type (CO) not provided.
6. Exit signage is not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to :-

1. The Addl. Commissioner of Police (Lic.), 1st Floor Police Station, Defence Colony,