

c-52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/SZ/ 482
To

Dated: 01 / 11 /2021

The Dy. Health Officer, South Zone
SDMC, Public Health Department,
Green Park, Delhi 110016


Sub: Regarding issue of Fire Safety Certificate (FSC) in r/o M/s Sagar Ratna Restaurant (A Unit of Sager Ratna Restaurant Pvt Ltd) at C-2, GF & FF, Malviya Nagar, Main Market, New Delhi 110017.

Sir,

This is in reference to with MHA Portal Id No 2021072315739 dated 24/07/2021 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22/10/2021 in the presence of Sh. Manish Kumar (Cashier) and observed that the shortcoming intimated vide letter of even no. 350 dated 18/08/2021 has yet not been complied. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

Copy to

1. M/s Sagar Ratna Restaurant (A Unit of Sager Ratna Restaurant Pvt Ltd) at C-2, GF & FF, Malviya Nagar, Main Market, New Delhi 110017.

C-46

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/2021/SZ/ 350

Dated: 18/08/2021

To

The Dy. Health Officer, SDMC,
Public Health Department, South Zone,
Green Park, New Delhi 110016.

Sub: - Regarding Issue of fire Safety Certificate in r/o M/s Sagar Ratna Restaurant (A Unit of Sagar Ratna Restaurant Pvt Ltd) at C-2, GF & FF, Malviya Nagar, Main Market, New Delhi -110017.

Sir,

This has a reference to with MHA Portal ID 2021062814346 dated 22/07/2021, on the subject cited above. In this connection, it is to inform you that the above mentioned site was visited by the officer concerned of this department on dated 04/08/2021 in the presence of Sh. Prabhakar (Manager) and observed that terrace level pump capacity 450 LPM not working and there is a additional construction has been constructed at half portion of 4th floor of the building and there changed in the building constructed vis a vis FSC issued by this department letter of even no 2112 dated 14/09/2018.

In view if above, it is requested that a complete two set of approved/sanctioned building plans (current occupancy) including section/elevation/lay out plan on the scales as mentioned in UBBL 2016 duly marked with fire and life safety systems as per NBC part 4 are required to assess the fire and life safety requirements. However if approved/sanctioned plans are not available than a set of complete building plans shall be forwarded through concerned building sanctioning authority/ local authority for further consideration in the matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR

DM

Copy to: -

1. M/s Sagar Ratna Restaurant (A Unit of Sagar Ratna Restaurant Pvt Ltd) at C-2, GF & FF, Malviya Nagar, Main Market, New Delhi -110017.