

670

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/ 2021/ 772

Dated:-08/11/2021

To,

The Manager,
Today International,
Plot No.11,Block No.3,
D.B. Gupta Road, Pahar Ganj New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Today International, Plot No.11,
Block No.3, D.B. Gupta Road, Pahar Ganj New Delhi. ID No.2021090420135 dated 04.09.21.

Sir,

This has reference to on line 2021090420135 dated 04.09.21 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 29/10/2021 in the presence of Mr. Ajay Kumar and following shortcomings were observed: -

1. Fire Check Door of 01 hr. rating on the staircase are not provided as per Gazette Notification dated 27.05.2019.
2. Smoke Management system is not provided as per Gazette Notification dated 27.05.2019.
3. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully,


5/11/21

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.