

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/EH/2021/SZ/ 493  
 To

Dated: 02/...11/2021

The Dy. Health Officer,  
 SDMC, South Zone,  
 Green Park, Delhi- 110016

*Sub:* Issuance of NOC in r/o MS UBER (A unit of Ms Silver Spoon entertainment P Ltd.) M-42, Ground Floor, Greater Kailash- II Market, Delhi 110048

Sir,

This has reference to MHA Portal ID No. 2021072615916 dated 02/08/2021 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department in the presence of Mr. Neeraj Kumar (Manager) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. There are two doors having width of 1.0 mtr & 1.1 mtr against the required width of 1.50 mtr each respectively.
2. First Aid Hose Reel not provided.
3. The MOEFA system is not provided.
4. The Internal Hydrant not provided.
5. Terrace level Fire Pump capacity of 450 LPM not provided.
6. Overhead tank capacity 20,000 ltrs not provided.
7. Exit Singate not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
 (Atul Garg)  
 Director

Copy to:-

1. MS UBER (A unit of Ms Silver Spoon entertainment P Ltd.) M-42, Ground Floor, Greater Kailash- II Market, Delhi 110048
2. The Joint Commissioner of Police, 1<sup>st</sup> Floor, P.S Defence Colony, New Delhi 110049