

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F6/DFS/MS/School/WZ/2021 / 606

Dated: 11 / 11 /2021

To,

The Principal,  
Bal Bharati Public School,  
Pawana Road, Pitampura,  
Delhi-110034.

**Sub. :-Renewal of Fire Safety Certificate in r/o Bal Bharati Public School Located at Pawana Raod, Pitampura, Delhi-110034.**

Sir,


Please refer to your email dated 22.10.2021 on the subject cited above. In this connection it is to inform you that the said School building has been inspected by the officer concerned of this department on 18.10.2021 in presence of Sh. Pranab Bhattacharya (Caretaker) to check workability/functionability of Fire safety systems provided in the building.

**During inspection, the following shortcomings have been observed:-**

1. Fire Check Door is removed from the lift lobby.
2. Fire Pumps not found functional due to maintenance work in progress.

In view of the above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
(West Zone)

Copy to:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.