

e5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/EH/NDZ/2021/ 508

Dated..11/.11./2021

To,

The Manager  
M/S Biryani By Kilo (Sky Gate Hospitality Private limited)  
N-79, F.F. Block- N,  
Connaught Place, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Biryani By kilo ( Sky Gate Hospitality Private limited ) located at N-79, F.F. Block- N, Connaught Place, New Delhi. ID No 2021090720449 dated 18.09.2021.

Sir,

This has a reference to online ID No. 2021090720449 dated 18.09.2021 on the subject cited above, it is to inform you that the site was inspected by the officers concerned department on 27/10/2021 in the presence of Sh. Suresh and the following shortcomings were observed: -

1. 02 Staircases of 1.5 meter each are not provided.
2. 02 Exits of 1.5 meter each are not provided.
3. First aid hose reel and hydrant systems are not provided.
4. MOEFA is not provided.
5. Terrace pump of 450 LPM is not provided.
6. Overhead fire water tank of 20,000liter capacity is not provided.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
DIRECTOR

Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.),  
Licensing Unit, Defense Colony Police Station, New Delhi