

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2021/NDZ/612

Dated: 18/11/2021

To,

The Principal,
EDMC Primary School,
Mansarovar Park East,
Shahdara, Delhi-110032

Subject:- Request for issue NOC for fire work.

Sir,

With reference to email ID eee2shahnorthzone@gmail.com dated 04/10/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Sh. Parveen Kumar Sharma, Principal of the school on dated 29/10/2021. The school building comprises of ground plus two upper floors. During the course of inspection following observations were made:-

1. A fire pump with 450 liters per minute discharge at 40 meters head (4kgf/sq.cm.) is required to be provided at terrace level.
2. An overhead water tank having 10,000 liters is required to be provided exclusively for fire fighting systems.
3. Hose reels containing 30m of length and 20mm bore terminating in to a shut-off nozzle of 5mm outlet connected to the pump shall be provided for every 1000sqm. of covered area subject to a minimum of one hose reel per floor of the school building, are required to be provided.
4. Exit signs are required to be provided in the school building at all exits.
5. Sanctioned/Completion plans or as built plans (on the scale of 1:100 having details of height/covered area, year of construction/conversion of occupancy duly marked with fire and life safety arrangements as stipulated under Rule 33 of Delhi Fire Service Act of Rules 2010) through building/local authority, in case sanctioned/completion plans are not available.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,

(Atul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj Industrial Area, Delhi-110092