

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/School/2021/NDZ/609

Dated: 18/11/2021

To,

The Principal,
St. Andrews Scots School,
G-26, Jagat Puri, Street No. 17,
Parwana Road, Delhi-110051

Subject:- Renewal of Fire Certificate.

Sir,

With reference to your email ID standrewsjagatpuri@gmail.com dated 30/09/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Mr. Azmat Khan on dated 25/10/2021. The school building comprises of ground plus three upper floors. During the course of inspection following observations were made:-


1. An overhead water tank having 10,000 liters capacity is required to be provided exclusively for firefighting systems.
2. Exit signs are required to be provided in the school building at all exits.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours Faithfully,



(Dr. S. K. Tomar)
Dy. Chief Fire Officer



Copy to:-

The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053