

C 49

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001**

No. F6/DFS/MS/GH/NDZ/2021/ 845

Dated: 25/11/2021

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **Al-Ahad Holiday Home at 977, Bazar Matia Mahal, Jama Masjid, Delhi.**

Sir,

With reference to online application no. 2021101224009 dated 12.10.2021 regarding the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 16.11.2021 in the presence Mr. Arshad (Manager) and it was observed that building is comprised of Ground + 03 upper floors. During inspection, following shortcomings were observed.

1. Fire Extinguishers found non functional.
2. First Aid Hose reels found non functional.
3. CO detectors with panel and alarm not provided in the guest house as required in Gazette Notification dated 27.05.2019.
4. Fire pump found non functional.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is cannot be considered at this stage. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
22/11/21

**((Dr. S.K. Tomar))**

Dy. Chief Fire Officer

Tel: 011-23412025

OTC 86  
18/11

**Copy to:-**

The Licensee,  
Al-Ahad Holiday Home at 977, Bazar Matia Mahal, Jama Masjid, Delhi.