

C-77

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI- 110001

No.F6/DFS/MS/GH/NDZ/ 2021/ 838

Dated:-22./11/2021

To,

The Manager,
Arjun Dx. Guest House, 2977/3,
Chuna Mandi, Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Arjun Dx. Guest House at 2977/3,
Chuna Mandi, Pahar Ganj, New Delhi ID No. 2021101424265 dated 19/10/2021.

Sir,

This has reference to on-line ID No. 2021101424265 dated 19/10/2021 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 09/11/2021 in the presence of Mr. Nazim (Manager) following shortcomings were observed: -

1. Smoke Management system is not provided as per Gazette Notification dated 27.05.2019.
2. CO type detectors are not provided as per Gazette Notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.