

26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2021/ 528

Dated:-22./11/2021

To

The Manager,  
M/S CHIDO (Good Time Foods Private Ltd.),  
M-18, Ground floor, Outer Circle, Connaught Circus,  
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S CHIDO (Good Time Foods Private Ltd.) at M-18, Ground floor, Outer Circle, Connaught Circus, New Delhi. Online ID No. 2021091821850 dated 22.09.21.

Sir,

This has reference to Online ID No. 2021091821850 dated 22.09.21 on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 02/11/2021 in the presence of Sh. Mohit Chug, and following shortcomings were observed:-

1. Alternate staircase of 1.5 meter is not provided for the mezzanine floor.
2. First aid hose reel provided but found nonfunctional.
3. Size of down comer of hydrant systems is not provided as per IS 3844/1989.
4. Terrace pump of capacity 450 is not provided.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

(Atul Garg)  
DIRECTOR

Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony, Police Station, New Delhi