



e:80

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2021/WZ/ 536
To,

Dated: 25/11/2021

MR. Sehaj Bhasin,
House No.121, Triveni Apartments,
West Enclave Pitampura,
Delhi-110034.

Sub: Issue of FSC in r/o M/s Darpann Kitchen & Bar at D-3, , D-Block, 3rd floor, Progressive Tower Central Market, Prashant Vihar, Rohini, Delhi-110085.

Sir,

This is in reference to your online application No. 2021021610466 dated 17.02.2021 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **25.10.2021**, in presence of **Sh. Manav (Authorized Signatory)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The alternate exit of required width of 1.5m is not provided.
2. The width of exits is 1.10m against the required width of 1.5 mtr.
3. Smoke management system in restaurant is not provided.
4. Fire protection system not provided as per NBC Part-IV
5. 10,000 ltrs under ground water captive tank not provided.

advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully

(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to:

1. M/s Darpann Kitchen & Bar at D-3, , D-Block, 3rd floor, Progressive Tower Central Market, Prashant Vihar, Rohini, Delhi-110085