

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No.F6/DFS/MS/School/NDZ/2020/84

Dated: 11/02/2021

To

The Principal,
Nigam Pratibha Co-Ed School,
Phool Mandi, Daryaganj, New Delhi-02

Subject:-Regarding renewal of Fire Safety Certificate in r/o Nigam Pratibha Co-Ed School, Phool Mandi, Daryaganj, New Delhi-02

Sir,

This has reference to email letter dated 28.01.2021 on the subject cited above, it is informed that the School building was inspected by Assistant Divisional Officer (SPM) from this department on 02.02.2021 in the presence Mrs. Chaman Bano, Principal and it was observed that the building which was earlier comprised of ground and first floor is now comprised of ground + 02 upper floors and hence is a case of addition/alteration. The fire and life safety requirements applicable are as prescribed in Unified Building Byelaws 2016 and National Building Code 2016 as the year of construction of additional floor is 2019.

During inspection following shortcomings were observed.

1. First Aid Hose reels not provided.
2. Fire pump having capacity 450 LPM with 40 m head not provided.
3. Over head water storage tank 10,000 liters capacity for firefighting not provided.
4. Exit signs not provided

In view of the above shortcomings, the Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel:-011-23414000

a/c 
10/2

Copy to:-

The Directorate of Education,
North Delhi Municipal Corporation, City S.P. Zone, Old Hindu College, Kashmiri Gate, Delhi