

67

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F6/DFS/MS/Restaurant/2021/NDZ/ 529

Dated: 22/11/21

To,

Mayur's Urban Spice
B-1, main 100 feet road, Chajjupur,
Near Durgapuri, Shahdara , Delhi-110094

Sub :- Regarding Issuance of Fire Safety Certificate in r/o Mayur's Urban Spice B-1,
main 100 feet road, Chajjupur, Near Durgapuri, Shahdara, Delhi-110094.

Sir,

With reference to your online application No. 2021092222224 dated 28/08/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned restaurant from fire safety point of view in presence of Mr. Praveen Choudhary (Manager). During the course of inspection the following shortcomings were observed.

1. Exit door of 1.50 meters wide is not provided.
2. Fire Extinguisher not provided.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Copy to:-

1. The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi
2. The Commissioner (EDMC)
Plot No 419, Patparganj Industrial Area,
Delhi-110092