

0.35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/School/2021/ 614

Dated 22/ 11/2021

To,

The Principal
Panacea National Public School,
Libaspur Road Siraspur, Delhi-110042.

Sub: - Regarding issuance of fire safety certificate in r/o Panacea National Public School, Libaspur Road Siraspur, Delhi-110042.

Sir,

This has reference to your letter no. PNPS/2021/DFS/021 dated 12.10.2021 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 09.11.2021 in presence of Sh. Sunil Kumar (Manager) to verify the compliance of the shortcomings issued by this department vide letter of even no. 1837 dated 21.07.2017 and observed that the shortcomings have not been complied in Toto.

Keeping in view of above, Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Garg)

Director

Ph: 011-23414250

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

NO. *F6/DFS/MS/2017/1837*

Date: *21 / 7 / 2017*

To
The Principal,
Panacea National Public School,
Libaspur Road Siraspur,
Delhi-110042.

Sub:- Regarding fire safety certificate in respect of Panacea National Public School, Libaspur Road Siraspur, Delhi-110042
Sir,

Please refer to your letter No PNPS/DFS/2017 dated 20/05/2017 on the subject cited above. In this connection this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department along with school authority on 07/07/2017, the building was earlier comprised of ground + one upper floor and presently ground + two upper floors. However following shortcomings were observed:

1. The width of two staircase is 1.10 mtr each provided against the required width of two staircases of 1.5 mtr each.
2. Hose reels not provided.
3. Terrace Fire pump with capacity 450 LPM not provided.
4. Over Head water captive tank of 10,000 ltrs not provided.
5. Exit signage not provided

You are requested to comply the shortcoming under intimation to this department

Yours faithfully

(Signature)
Atul Garg)
Chief Fire Officer
Ph: 011-23414250

(Signature)